

TENT PERMIT

Date: _____

Field Inspector _____ **Tent/Canopy SF** _____ **Ref#** _____
Permit Activation Date _____ **Expiration Date** _____ **Fire Planner Initials** _____
Tent/Canopy Installation Date _____ **Removal Date** _____
Project Address: _____ **City** _____ **Zip** _____
Location of Tent _____ **Map Reference Page** _____
Applicant: _____ **Application Date:** _____
Company Name _____ **Project Name** _____
Phone _____ **Mobile** _____
Tent Contractor: _____ **Phone** _____

Call Inspection Request Line for Tent/Canopy Inspection (916) 774-5800

Roseville Fire Department in pursuant to the 2001 California Fire Code, Article 32 requires a temporary permit for a tent/canopy. Two sets of plans must be submitted for approval before installation followed by an inspection after the tent/canopy has been erected, and before it is occupied.

The following is a list of requirements.

- 1) A site plan showing an unobstructed fire lane on all sides of the tent. The tent cannot block any fire hydrants or fire department connections.
- 2) A flame resistant certificate by an acceptable testing laboratory.
- 3) A note on the submitted plan stating "NO SMOKING" signs will be posted.
- 4) A note on the submitted plans stating, "a 2A-10BC fire extinguisher will be provided and mounted no higher than 48" above finished floor to the handle."
- 5) A note on the submitted plan stating, "no smoking, no fireworks, no open flames or devices emitting open flame or fire will be used in the tent/canopy."
- 6) An inspection of the tent, by the Roseville Fire Department, shall take place prior to occupying the structure. Please contact the Fire Prevention Division at 774-5800.

I accept this permit under the conditions stated and declare that I am the owner or legal occupant of the property upon which the tent is to be erected, or that I have the permission of the property owner. I understand that this permit is valid only for the date and time specified.

Signature of Fire Department Personnel: _____

Date Issued _____

