



Roseville Fire Department

Fire & Life Safety Division

316 Vernon Street Suite 480 · Roseville, CA 95678 · (916) 774-5800 · FLSDivision@roseville.ca.us

AST Removal Permit

Please submit all completed permit applications to FLSDivision@roseville.ca.us

Permit applications shall be submitted at least 10 days prior to the event. One-time permit only.

Facility Name: _____ Facility Address: _____

Emergency Contact: _____ 24 hr. Phone Number _____

Contractor Name: _____ Contractor Address: _____

Contractor Phone Number: _____ Contractor Email: _____

Contractor License Number: _____ Contractor License Expiration Date: _____

1. The Roseville Fire & Life Safety Division shall be notified at least 48 hours prior to any inspections. Call (916) 774-5800 or email to schedule inspections.
2. I/we do absolve the Roseville Fire Department, or any member thereof, of any and all liability for damage of any kind whatsoever that may occur as a result of this operation.
3. Licensed operator will conform to all requirements as contained in the California Code of Regulations.
4. Tank removal and sampling activities (if required) must be witnessed by a Fire and Life Safety Inspector.

The following documents must be provided with this application:

- | | |
|---|---|
| 1. Site Map | 5. Location the tank will be shipped to |
| 2. Location the remaining product will be shipped | 6. Tank transporter information |
| 3. Tanks size and substance contained | 7. Proof of insurance, licenses, and certifications |
| 4. Scope of work | 8. Equipment to be used |

AST removal shall comply with all requirements listed below and within the current California Fire Code:

1. Hazardous materials shall be removed from tanks and piping prior to tank removal and must be properly managed. Materials generated as the result of the rinsing or decontamination of tanks shall be managed as hazardous wastes unless a written hazardous waste determination per Title 22 California Code of Regulations §66262.11 demonstrates that the waste is non-hazardous.
2. All pumps and associated piping shall be removed.
3. The person removing the tank(s) shall provide tank removal/lifting equipment of a size adequate to safely lift the tank(s) onto the transport vehicle without dragging them or otherwise causing an unsafe condition.
4. For tanks previously containing flammable/combustible materials, the person closing the tank(s) shall provide, on-site and readily accessible, at least one 40BC rated portable fire extinguisher and a properly calibrated meter capable of measuring LEL (Lower Explosive Limit) and oxygen levels.
5. Tanks previously containing flammable/combustible materials shall be made safe for removal by the addition of dry ice (carbon dioxide) — or other methods approved by the local agency — sufficient to achieve an atmosphere of either less than 10% oxygen or less than 20% LEL. *(Note: At a minimum add 22.2 pounds of dry ice per 1,000 gallons of tank volume; however, highly volatile materials may require more.)*
6. A copy of the TSDF-signed copy of any Uniform Hazardous Waste Manifest or Consolidated Manifest used to transport tanks, piping, and/or contents.
7. The operator of the facility shall update the facility's Hazardous Materials Business Plan (HMBP) within 30 days via the California Environmental Reporting System (CERS) at cers.calepa.ca.gov

In affirming my signature hereon, I realize that as the permittee, I am responsible for compliance with all provisions under which this permit may be granted. Application or permit does not replace any license or permit required by any other agency.

Applicant's Signature: _____ Date: _____

Permit Authorized By: _____ Issue Date: _____